

Annual Water Quality Report for 2022
Village of Greenwich
6 Academy Street, Greenwich, NY 12834
(Public Water Supply Identification Number NY5700122)

INTRODUCTION

To comply with State regulations, the Village of Greenwich, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report is an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to New York State standards. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. If you have any questions concerning this report or concerning your drinking water please contact: *Mr. John Hogan, Water Treatment Plant Operator, 6 Academy Street, Greenwich, NY 12834; Telephone (518) 703-1546.* We want our valued customers to be informed about their drinking water. If you want to learn more, please attend any of our regularly scheduled Village Board meetings. They are held on the 2nd Monday of each month, 7:00 PM at the *Community Center, 6 Academy Street; Telephone (518) 692-2755.*

WHERE DOES OUR WATER COME FROM?

The Village is served by three drilled wells located on Eddy Street, County Route 74 in the Village of Greenwich. Well #1 consists of a drilled well 56-feet deep with a 6-inch casing. The well was developed and used by the Village in 1957. Well #2 was also developed in 1957 and consists of a drilled well 55 feet deep with a 6-inch casing. Well #3 is a 60-foot drilled well with a 6-inch casing and was developed in 1980. All the wells are redeveloped and inspected on a rotating basis once every three years. The maximum peak daily demand for water in the summer months has reached 400,000 gallons. Pumping capacity for each well is approximately 185 gallons per minute. We have a 560,000-gallon storage tank located on Prospect Street in the Village to meet consumer demand and to provide adequate fire protection. Because our wells were designated as Ground Water Under the Direct Influence of Surface Water (GWUDI) we were required to install a filtration plant. We have a chlorine contact loop which increases the required contact time to provide adequate microbial disinfection. Our cartridge filtration plant consists of two filter vessels with a 5-micron filter followed by a 1 micron polishing filter. A 560,000-gallon storage allows us to meet consumer demand and to provide adequate fire protection. Two new wells have been drilled and will be tied into the treatment plant.

We have experienced lower pumping capacity on our wells at various times and need to increase our source capacity. We are under a judicial order from the New York State Department of Health Glens Fall District Office (NYSDOH GFDO). In addition, the transmission main from the treatment plant to the Village must be replaced. The deadline for completion of these projects was extended to December 31, 2022. Installation of two replacement wells was completed and we are working with the Department of Health and our engineers to complete connection of these wells to the system and address the other needed system improvements.

We are under an Administrative Order from the NYSDOH to improve the distribution system. We are currently working with our consulting engineers to make improvements to the distribution system

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations, which limit the amount of certain contaminants in water, provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

FACTS AND FIGURES

The Village provides water through 881 service connections to a population of approximately 2000 customers. Our average daily demand is 232,000 gallons. Our single highest day was 283,000 gallons. In 2022 the Village pumped 84,681,000 gallons of water.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

In accordance with State regulations, the Village of Greenwich routinely monitors your drinking water for numerous contaminants. We test your drinking water for inorganic contaminants, radiological contaminants, lead and copper, nitrate, volatile organic contaminants, haloacetic acids, trihalomethanes and synthetic organic contaminants. In

addition, we test 2 samples for coliform bacteria each month. The table presented below depicts which contaminants were detected in your drinking water. The state allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old and is noted.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health Glens Falls District Office at (518) 793-3893.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our monitoring and testing that some contaminants have been detected; however, these compounds were detected below New York State requirements.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2022, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbiological pathogens are available from the Safe Drinking Water Hotline (800-426-4791)

INFORMATION ON LEAD

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Greenwich Water Department is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Mr. John Hogan, Village of Greenwich Water Department (518) 581-8626. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>

VILLAGE OF GREENWICH TABLE OF DETECTED CONTAMINANTS Public Water Supply Identification Number NY5700122							
Contaminant	Violation Y/N	Date of Sample	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants (sample data from 7/30/20 unless otherwise noted)							
Barium (from 7/28/21) Well#3 Raw	N	7/25/22	116	µg/l	2000	MCL=2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Barium (from 7/28/21) Water Treatment Plant (WTP)		7/25/22	89.6				
Chloride	N	7/30/20	32.9	mg/l	N/A	MCL=250	Geology; Naturally occurring
Chromium	N	7/25/22	1.2	µg/l	100	MCL=100	Discharge from steel and pulp mills; Erosion of natural deposits.
Copper Range of copper concentration	N	9/28/20	0.115 ¹ 0.0195- 0.138	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Range of lead concentration	N	9/28/20	2.3 ² ND-3.7	µg/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Manganese Well#3 Raw	N	7/25/22	131	µg/l	N/A	MCL=300	Naturally Occurring
Manganese WTP	N		9.55				
Nickel (from 7/28/21)) Well#3 Raw	N	7/25/22	0.9	µg/l	N/A	N/A	Naturally Occurring
Nickel (from 7/28/21)) WTP	N	7/25/22	0.9				
Nitrate (as Nitrogen) (from 7/28/21)) Well#3 Raw	N	7/25/22	0.776	mg/l	10	MCL=10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate (as Nitrogen) (from 7/28/21)) WTP	N	7/25/22	1.17				
Odor	N	7/30/20	1	units	N/A	MCL=3	Natural sources
pH	N	7/30/20	7.49	units		6.5-8.5	Naturally Occurring
Sodium ³	N	7/30/20	19.2	mg/l	N/A	N/A	Naturally Occurring, Road salt
Sulfate	N	7/30/20	14.2	µg/l	N/A	MCL=250	Naturally occurring
Radiological Contaminants							
Gross Alpha	N	7/29/20	3.66	pCi/l	0	MCL=15	Erosion of natural deposits
Microbiological Contaminants							
Highest Turbidity (Highest Turbidity)	N 100%		0.75 ⁴	NTU	N/A	TT=5 TT=95% of samples <1.0	Soil Runoff
Stage 2 Disinfection Byproducts (samples from 7/30/21 unless otherwise noted)							
Chlorine (average) Range of chlorine residuals (based on daily testing)	N	Daily Testing	0.55 0.82-1.17	ppm	N/A	MCL=4	Used in the treatment and disinfection of drinking water
TTHM [Total Trihalomethanes] average range	N	7/25/22	10.5	µg/l	N/A	MCL=80	By-product of drinking water chlorination
Haloacetic Acids [HAA5] average range	N	7/25/22	4.43	µg/l	N/A	MCL=60	By-product of drinking water chlorination
Total Organic Carbon (quarterly samples 2022)							
Raw Water	N	Quarterly samples 2022	1.27-3.61	mg/l	N/A	TT	Organic material both natural and man made
Raw Water E. coli Testing Round 2 LT2ESESWTR ⁵ (Biweekly for a total of 26 samples) 10/17/17 thru 9/18/18							
Raw Water average range	N		10/3/17- 9/18/18	<1 ND-1	E. coli/100 ml	N/A	Average > 100 E. coli

FOOTNOTES-

1. The level presented represents the 90th percentile of 10 test sites. The action level for copper was not exceeded at any of the 10 sites tested.
2. The level presented represents the 90th percentile of 10 test sites. The action level for lead was not exceeded at any of the 10 sites tested.
3. Water containing more than 20 mg/l should not be consumed by persons on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.
4. Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of our filtration system. Level detected represents the highest-level detected. Our highest single turbidity measurement for the year 0.64 NTU occurred on State regulations require that entry point turbidity must always be below 1.0NTU. The regulations also require that 95% of the turbidity samples collected have measurements below 0.3 NTU. We met the requirement 100% of the time in 2022.
5. Under the LT2 (Long Term Enhanced Surface Water Treatment Rule, small surface water or GUIDI systems could monitor for E. coli biweekly for 1 year instead of performing the more costly Cryptosporidium/Giardia testing to determine treatment requirements for their water sources. An average E. coli concentration greater than 100/100 ml of sample would trigger Cryptosporidium and Giardia monitoring for 24 months.

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

90th Percentile Value - The values reported for lead and copper represent the 90th percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead and copper values detected at your water system

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Locational Running Annual Average (LRAA): The LRAA is calculated by taking the average of the four most recent samples collected at each individual site

N/A-not applicable

WHAT IS THE SOURCE WATER ASSESSMENT PROGRAM (SWAP)?

To emphasize the protection of surface and ground water sources used for public drinking water, Congress amended the Safe Drinking Water Act (SDWA) in 1996. The amendments require that New York State Department of Health's Bureau of Public Water Supply Protection is responsible for ensuring that source water assessments are completed for all of New York's public water systems.

A source water assessment provides information on the potential contaminant threats to public drinking water sources:
each source water assessment will: determine where water used for public drinking water comes from (delineate the source areas)

- ◆ Inventory potential sources of contamination that may impact public drinking water sources
- ◆ Assess the likelihood of a source water area becoming potential contaminated

A SWAP summary for our water supply is attached to this report.

CAPITAL IMPROVEMENTS

In 2021 the following projects are planned:

- ◆ Replace transmission main between the Treatment Plant and Bridge Street.

WATER CONSERVATION TIPS

The Village of Greenwich encourages water conservation. There are a lot of things you can do to conserve water in your own home. Conservation tips include:

- ◆ Only run the dishwasher and clothes washer when there is a full load
- ◆ Use water saving showerheads
- ◆ Install faucet aerators in the kitchen and the bathroom to reduce the flow from 4 to 2.5 gallons per minute
- ◆ Water gardens and lawn for only a couple of hours after sunset
- ◆ Check faucets, pipes and toilets for leaks and repair all leaks promptly
- ◆ Take shorter showers

CLOSING

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit our customers. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

Greenwich Village
PWSID# NY5700122
Source Water Assessment Summary

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated our wells as having an elevated susceptibility to microbials. These ratings are due primarily to the agricultural/pasture land use in the assessment area. In addition, the wells are high yielding wells that draw from an unconfined aquifer, which is a shallow aquifer that occurs immediately below the ground surface and has no overlying protective layer for protection from potential sources of contamination. While the source water assessment rates our well(s) as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination.

The county and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning and education programs. A copy of the full Source Water Assessment, including a map of the assessment area, is available for review by contacting us at the number provided in this report.